


**Copy of the Water Health and Sanitation Certificate Issued By Taluka
Health Officer, Taluka Health Office, Jewargi**



Government Of Karnataka



**Taluka Health Office
HOSPITAL COMPOUND. JEWARGI**

E-mail: thojewargi@gmail.com

Office Phone Number: 08442 - 236339

No/THOJ/ Staff / /2025-26

Dates: 11-03-2026

It is a certified an inspection team headed by Dr UMESH SHARMA designation TALUKA HELTH OFFICER, JEWARGI, KARNATAKA inspected the SRE INTERNATIONAL SCHOOL, MUDABAL B AT POST MUDABAL B TA. JEWARGI, DIST. KALABURAGI, KARNATAKA on 11.03.2026 and on the basis of water Test report (attached) bearing no. DFL/KLB/N-PVT/WATER/003/2026/168 Dated 09.03.2026 of DIVISIONAL FOOD LABORATORY KALABURAGI DIVISON certified that the SRE INTERNATIONAL SCHOOL has safe drinking water facilities for the students and member of staff of the institution school is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the central/State/U.T Govt.

The certificate is valid till one year

To.

THE PRINCIPAL

SRE INTERNATIONAL SCHOOL

MUDBAL (B) TQ JEWARGI

DIST KALABURAGI

school is

per norms

The certifi

Taluka Health Officer
ಕರ್ನಾಟಕ ಸರ್ಕಾರ
Jewargi

PRINCIPAL

**SRE International School
Mudabal (B) Tq. Jewargi
Dist Kalaburgi - 585310**

PRESIDENT
**SR Educatekids Educational
Charitable Trust, JEWARGI**

Copy of the Water Examination Report



GOVERNMENT OF KARNATAKA
Divisional Food Laboratory Kalaburagi Division
First Floor, Central Bus Stand, Kalaburagi - 585102
Phone: 08472-260427 E mail: dfgulabarga@gmail.com

No: DFL/KLB/N-PVT/WATER/003/2026/168

Date: 09.03.2026

To
SRE International School
Mudabal (B) Tq. Jewargi,
Dist. Kalaburagi.

Ref. No: Nil; Date : 06.03.2026;

Received One Water sample from SRE International School Mudabal(B) Kalaburagi
for analysis. Received on : 06-03-2026;
Challan No.: CR0326021000177286; Date : 07/03/2026; Bank : SBI Kalaburagi; Amt: 5000
Date of analysis : 07.03.2026 To 09.03.2026

Method: FSSAI Manual Method.

Sl No	Quality Characteristics	Results Mg/l. (Except pH and turbidity)	Requirement as per IS 10500:2012 Mg/l. Max.	Permissible limit as per IS 10500:2012 in the absence of alternate source Mg/l. Max.
1	Odour	Agreeable	Agreeable	Agreeable
2	Taste	Agreeable	Agreeable	Agreeable
3	pH	8.2	6.5-8.5	No relaxation
4	Turbidity	0.1	1	5
5	Total dissolved solids	48.53	500	2000
6	Total Hardness (as CaCO_3)	40.0	200	600
7	Calcium (as Ca)	8.0	75	200
8	Chlorides (as Cl)	34.0	250	1000
9	Alkalinity	8.0	200	600
10	Magnesium (as Mg) mg/l, Max	4.88	30	100
11	Flouride (as F)mg/l,Max	0.17	1.0	1
12	Nitrate(as NO_3)mg/l,Max	3.2	45	No relaxation
13	SULPHATE(as SO_4)mg/l,Max	3.08	200	400
14	Iron(as Fe),mg/l,Max	0.055	0.3	No relaxation
15	Conductivity	160.1	-	-
16	Physical appearance	Satisfactory	Satisfactory	Satisfactory

Opinion:- The Water Sample conforms to the standards of purified drinking water as per
above mentioned parameters.

"End of Report"

Page 1 of 1

07/03/2026
CHIEF FOOD ANALYST
DIVISIONAL FOOD LABORATORY
KALABURAGI DIVISION, KALABURAGI

PRINCIPAL
SRE International School
Mudabal (B) Tq. Jewargi
Dist Kalaburagi - 585310

PRESIDENT
SR Educatekids Educational
Charitable Trust, JEWARGI